

SAFE DRINKING WATERNO. 132Date: 28/02/26

It is certified that an Inspection team headed by **UDAY CHAND RAM**, (Name of Officers with designation) from ASSISTANT ENGINEER, P H. SUB DIVISION , GAYAJI (Name of department/Office) inspected the SUBHASH INTERNATIONAL SCHOOL, AURWAN TOLA, KISHUNPURA, GAYAJI 823004 (BIHAR) (Name & Address of the School) on 19.02.2026 and on the basis of Water Test Report (attached) bearing no. 3/2026.dated 23.02.2026 of (PHED Lab) certified that facilities for the students and members of staff of the institution. The campus as per the norms prescribed by the Central/State/U.T. Govt.

This certificate is valid till ONE YEAR.

Signature :

Name :.

(UDAY CHAND RAM)

Designation : ASSISTANT ENGINEER

Name & Add. Of Department/ Office: P.H
SUB DIVISION, GAYA JI WEST, GAYA JI

25/02/26
Assistant Engineer
P.H. Sub Division, Gaya West
Gaya

To,

SUBHASH INTERNATIONAL SCHOOL
AURWAN TOLA, KISHUNPURA,
GAYAJI - 823004 (BIHAR)
(Name & Address of the Institution)

Govt. of Bihar
DISTRICT LEVEL WATER QUALITY TESTING LABORATORY (DLWQTL)
Public Health Engineering Department
P.H. DIVISION, GAYA

Physico-Chemical and Bacteriological Examination Report of Drinking Water Samples of Gaya																			
Sample Collected By :	Upendra kumar	SUBHASH INTERNATIONAL SCHOOL AURWANTOLA KISHUNPUR GAYA								Sample Received on : 13/02/26									
Sample no	Block Name	Panchayat Name	Village	ward no	Turb.	Conductivity	TDS	Hardness	Calcium	Magnesium	Chloride	Alkalinity	Fluoride	PH	Nitrate	Iron	Sulphate	Bacteria (+/-)	Remarks
1	TOWN	TOWN	TOWN	TOWN	0.29	330	214	164	57.72	0.12	67.98	188	0.47	7.34	-	-	40	Absent	
Reporting Date :	17.02.26	Desirable Limit			1.00 NTU	-	500 (mg/l)	200 (mg/l)	75 (mg/l)	30 (mg/l)	250 (mg/l)	200	1.00 (mg/l)	6.5- 8.5	45 (mg/l)	1.00 (mg/l)	200 (mg/l)	Absent	
Permissible Limit in absence of alternate source IS:10500:2012					5.00 NTU	-	2000 (mg/l)	600 (mg/l)	200 (mg/l)	100 (mg/l)	1000 (mg/l)	600 (mg/l)	1.50 (mg/l)	NR	NR	NR	400 (mg/l)	Absent	

*NR-No Relaxation.,BDL-Below Detection Limit

Rajesh
Chemist 17.02.26

P.H. Division, Gaya

जल नमूना का संग्रह दिनांक 13.02.26
 Upendra kumar के द्वारा किया गया है ।